

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 01Date: 24/4/25

It is certified that an inspection team headed by Suraj Negi (Chemist)
(Name of Officers

with designation) from Uttarakhand Jal Sansthan Karnaprayag (Name of
Department/Office) inspected the ATAL UTKRISHT GOVT. INTERMEDIATE

COLLEGE SIMLI CHAMOLI (Name & Address of

the School) on _____ and found that the ATAL UTKRISHT GOVT.

INTERMEDIATE COLLEGE SIMLI CHAMOLI (Name of school) has safe

drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

Signature with Seal :


असिक्त अभियन्ता
उत्तराखण्ड जल संस्थान
कनप्रयाग (चमोली)

Name :

: Er. O. C. Purohit

Designation :

: A.E.

To

PRINCIPALATAL UTKRISHT GOVT.INTERMEDIATE COLLEGE SIMLI

(Name & Address of the Institution)

CHAMOLI



UTTARAKHAND JAL SANSTHAN KARANPRAYAG (CHAMOLI)

Water Quality Testing & Monitoring Laboratory Analysis Report

Name Of UJS Division	Uttarakhand Jal Sansthan, Karanprayag (Chamoli)
Name Of Block	Karanprayag
Name Of Scheme	Atal Utkrisht Govt. Inter College Simli (Chamoli)
Type Of Source	Tap Water
Date of Sample Collection	23/04/2025
Date of Sample Receipt in Laboratory	23/04/2025
Date of commencing examination	24/04/2025
UJS Representative	Name - Er. D C Purohit
	Designation - A E

LAB TESTING DETAILS

S.N	Quality Parameter	Unit Of Measurement	B I S Desirable Limit	B I S Permissible Limit	Actual Level
1	PH	mg/l	6.5	8.5	7.72
2	Total Dissolved Solids	mg/l	500	2000	132
3	Turbidity	NTU	1	5	0.81
4	Residual Free Chlorine	mg/l	0.2	1	0.0
5	Chloride	mg/l	250	1000	5.5
6	Alkalinity as CaCo ₃	mg/l	200	600	56
7	Total Hardness	mg/l	200	600	60
8	Calcium	mg/l	75	200	16.8
9	Magnesium	mg/l	30	100	4.87
10	E-Coli	MPN/100 ml	0	0	-
11	Total Coliform	MPN/100 ml	0	0	-
12	Colour	Hazen	5	15	5
13	Odour	-	-	-	Agreeable
14	Taste	-	-	-	Agreeable

(Suraj Negi)

Chemist

SUB-DIVISIONAL LEVEL
WATER QUALITY TESTING
MONITORING LABORATORY
UJS KARANPRAYAG, CHAMOLI